

**NAVAL STATION NORFOLK & NSA HAMPTON ROADS HEADQUARTERS  
COMPLEX WATERWORKS  
LEAD AND COPPER INDIVIDUAL RESULTS  
(June - September 2016)**

No.	Installation	Sampling Site	Lead (ppb)	Copper (ppb)
1	NSN	O25	9	494
2	NSN	SP367	5	383
3	NSN	SDA334	5	144
4	NSN	W388	90 <sup>th</sup> Percentile = 4	90
5	NSN	CEP188	3	248
6	NSN	CEP87	3	213
7	NSN	X380	2	160
8	NSN	X218	2	168
9	NSN	CEP204	2	88
10	NSN	P72	2	90 <sup>th</sup> Percentile = 261
11	NSN	SP12	2	184
12	NSA HR HQ	MCE2	2	118
13	NSN	X275	1	130
14	NSN	CEP201	1	79
15	NSA HR HQ	NH94	1	130
16	NSA HR HQ	BEN155	1	21
17	NSN	CEP166	Non-detect	62
18	NSN	CEP200	Non-detect	22
19	NSN	WB117 (8202 Oconner Cres.)	Non-detect	92
20	NSN	SP362	Non-detect	61
21	NSN	SP381	Non-detect	345
22	NSA HR HQ	MCA602	Non-detect	35
23	NSA HR HQ	MCA603	Non-detect	37
24	NSA HR HQ	CA495	Non-detect	139
25	NSA HR HQ	NH74	Non-detect	88
26	NSA HR HQ	MCE1	Non-detect	114
27	NSA HR HQ	INCHON1214	Non-detect	86
28	NSA HR HQ	INCHON1208	Non-detect	73
29	NSA HR HQ	INCHON1212	Non-detect	54
30	NSA HR HQ	INCHON1210	Non-detect	104

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value

Copper Action Level = 1300 ppb based on the 90<sup>th</sup> percentile value