



# NAVAL STATION NORFOLK & NSA HAMPTON ROADS, HEADQUARTERS COMPLEX NORFOLK, VIRGINIA 2018 CONSUMER CONFIDENCE REPORT



## Inside this issue:

<b>NSN/NSA HR Source Water</b>	<b>1</b>
<b>Definitions and Abbreviations</b>	<b>2</b>
<b>2018 Sampling Results Table</b>	<b>3</b>

Naval Station Norfolk and Naval Support Activity Hampton Roads, Headquarters Complex (NSN & NSA HR HQ Complex) are committed to providing you drinking water that is safe and reliable. NSN & NSA HR HQ Complex believe that providing you with accurate information about your water is the best way to assure that your water is safe. There were no drinking water violations to report for 2018.

Each year, the Consumer Confidence Report (CCR) is required to be distributed by July 1<sup>st</sup> of the current year. This CCR is a snapshot of the quality of your drinking water in 2018. The purpose of this annual report is to advise consumers of where their water comes from, provide water quality data, advance greater understanding of drinking water, and heighten awareness to conserve water resources.

## For additional information:

City of Norfolk Division of  
Water Quality  
757-441-5678  
<http://www.norfolk.gov/utilities/quality/default.asp>

Virginia Department of  
Health  
757-683-2000  
<http://www.vdh.state.va.us/drinkingwater/>

USEPA Safe Drinking  
Water Hotline  
800-426-4791  
<http://www.epa.gov/safewater/>

NSN/NSA HR HQ Complex  
Public Works Department  
Environmental  
757-341-0479/757-836-1862

*The source of NSN/NSA's drinking water includes eight reservoirs, two rivers, and four deep wells.*



## NSN & NSA HR HQ COMPLEX SOURCE WATER

NSN & NSA HR HQ Complex purchase drinking water from the City of Norfolk. Norfolk's primary water supply comes from eight reservoirs located in Norfolk as well as Suffolk/Isle of Wight County. Additionally, water sources include the Blackwater, and Nottoway Rivers and four deep wells located in Suffolk. From the reservoirs, water is pumped through pipes to the 37<sup>th</sup> Street Treatment Plant which is located in Norfolk. Water treatment chemicals are added to the water, causing small solid particles to clump together and sink to the bottom of a settling basin. The water is then filtered to remove bacteria, algae, and other impurities. Finally, the water is disinfected with chloramines to kill any remaining bacteria. The 37<sup>th</sup> Street Water Treatment Plant provides state of the art treatment technology and surpasses all state and federal water quality standards and regulations. In addition to the over 230 substances that are tested at the 37<sup>th</sup> Street Treatment Plant, Naval Station staff routinely monitors for bacteriological pathogens, disinfection byproducts, lead, and copper in order to meet federal and state regulations and to ensure the highest water quality possible.

## ABOUT DRINKING WATER

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances (referred to as contaminants) in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban storm water runoff, residential uses, and many other types of activities. Water from surface sources is treated while groundwater may or may not receive any treatment.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which may be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which may be naturally occurring, or the result of oil and gas production and mining activities.

In addition to these contaminants, all lakes and streams contain algae, which are microscopic plants that can cause taste and odor problems in drinking water.

## ABOUT DRINKING WATER (continued)

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) establishes limits for contaminants in bottled water, which must provide the same protection for public health.

### Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (800-426-4791).

Kidney dialysis patients should consult with their health care providers or dialysis centers in order to take special precautions when using chloraminated water. Fish owners should be sure chloramines are removed from the water before it is used in aquariums or ponds. Many pet stores sell water conditioners for chloraminated water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. The primary source of Lead in drinking water is materials and components associated with service lines and home plumbing. NSN & NSA HR HQ Complex are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components in buildings. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you have questions about your water, please contact NSN/NSA HR Environmental at 757-341-0479/757-836-1862. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



## DEFINITIONS AND ABBREVIATIONS

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The table on the following pages shows the results of monitoring for 2018. In the tables and elsewhere in this report you may find many terms and abbreviations which you are not familiar. The following definitions are provided to help you better understand these terms:

- **Action Level (AL)** - The concentration of a contaminant that, if exceeded in more than 10 percent of samples collected during any monitoring period, triggers treatment or other requirements which a water system must follow. For lead and copper monitoring, compliance is based on the 90th percentile value.
- **Level 1 Assessment** – A Level 1 assessment is a study of the waterworks to identify potential problems and determine, if possible, why total coliform bacteria have been found in our waterworks.
- **Level 2 Assessment** – A level 2 assessment is a very detailed study of the waterworks to identify potential problems and determine, if possible, why an *E. Coli* PMCL violation has occurred and why total coliform bacteria have been found in our waterworks on multiple occasions.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water based on running annual average. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. For chlorine and chloramines, a waterworks is in compliance with the MRDL when the running annual average of monthly averages of samples taken in the distribution system, computed quarterly, is less than or equal to the MRDL.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA** – Not applicable
- **Nephelometric Turbidity Unit (NTU)** – A measure of the clarity, or cloudiness, of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.
- **Non-detection (ND)** – Laboratory analysis indicates that the contaminant is not present.
- **Picocuries per liter (pCi/L)** - A measure of the radioactivity in water.
- **Parts per million (ppm) or Milligrams per liter (mg/L)** – A measurement of the amount of contaminant per unit of water. A part per million is one cent in \$10,000 or one minute in two years.
- **Parts per billion (ppb) or Micrograms per liter (ug/L)** – A measurement of the amount of contaminant per unit of water. A part per billion is like one cent in \$10,000,000 or one minute in 2,000 years.
- **Secondary Maximum Contaminant Level (SMCL)** – Non-enforceable standard that is established for aesthetic considerations
- **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

Delivered: 05 June 2019

### WATER QUALITY DATA

The tables below list only those contaminants that were present in your drinking water at levels detectable by laboratory equipment. Unless otherwise noted, the data presented in these tables is from testing done in 2018. We are required to monitor for certain contaminants less than once per year because the concentrations of these contaminants are less likely to change. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA sets the Maximum Contaminant Levels (MCLs) and the Maximum Contaminant Level Goals (MCLGs) as listed in the tables. The Regulated Substances Table and the Unregulated Substances Table are provided for your information and as required by the Consumer Confidence Rule.

### 2018 WATER QUALITY TABLE

Regulated Substances	Unit	MCLG	MCL	Highest Level	Average Level	Range	Meets EPA Standards	Possible Source of Contamination
2,4-D	ppb	70	70	0.3	ND	ND – 0.3	Yes	Agricultural Runoff
Atrazine	ppb	3	3	0.05	ND	ND-0.05	Yes	Agricultural Runoff
Barium	ppm	2	2	0.04	0.03	0.03 – 0.04	Yes	Erosion of natural deposits
Dibromochloropopane	ppb	0	0.20	0.01	ND	ND – 0.01	Yes	Agricultural Runoff
Fluoride	ppm	4	4	0.8 <sup>1</sup>	0.7	0.1-0.9	Yes	Added for the prevention of tooth decay
Gross Beta	pCi/L	0	50 <sup>2</sup>	4	4	ND - 4	Yes	Erosion of natural deposits
Nitrate as Nitrogen	ppm	10	10	0.19	0.13	0.08-0.19	Yes	Erosion of natural deposits—runoff
Total Organic Carbon	ppm	n/a	TT	3.1 <sup>1</sup>	2.4	1.5-3.3	Yes	Occurs naturally in environment

<sup>1</sup> Highest monthly average for calendar year <sup>2</sup> EPA considers 50 pCi/L to be the level of concern for Beta particles

LEAD AND COPPER* ( AT INSTALLATION'S TAP)	Units	EPA Limits		Your Drinking Water			Description/Typical Sources of Contaminants
		MCLG	AL	Samples Above AL	90 <sup>th</sup> PERCENTILE	Meets EPA Standards	
Lead (2016 data)	ppb	0	15	0 of 30	4	Yes	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (2016 data)	ppm	1.3	1.3	0 of 30	0.261	Yes	Corrosion of household plumbing systems; Erosion of natural deposits

\* Naval Station Norfolk is on a triennial monitoring schedule for Lead and Copper. The frequency of sampling is once every three years. The next sampling event will be in 2019.

Microbiological Contaminants	Unit	MCLG	MCL	Reported Level	Meets EPA Standards	Possible Source of Contamination
Total Coliform	% of positive samples	0	5% of monthly samples are positive	3.57%	Yes	Naturally present in the environment
E. Coli	# of positive samples	0	*	0	Yes	Human and animal fecal waste

\* Effective April 1,2016 The Revised Total Coliform Rule established the following Primary Maximum Contamination Level (PMCL): In compliance unless (i) the waterworks has an E. coli-positive repeat sample following a total coliform-positive routine sample; (ii) the waterworks has a total coliform-positive repeat sample following an E. coli-positive routine sample; (iii) the waterworks owner fails to take all required repeat samples following an E. coli-positive routine sample; or (iv) the waterworks owner fails to test for E. coli when any repeat sample tests positive for total coliform.

Residual Disinfectants and Disinfection By Products	Unit	MCLG	MCL <sup>1</sup>	Highest Level <sup>2</sup>	Range (Individual Results) <sup>3</sup>	Meets EPA Standards	Possible Source of Contamination
Haloacetic Acids (HAA5)	ppb	NA	60	39	0-41	Yes	Drinking water disinfectant by-product
Trihalomethanes (TTHM)	ppb	NA	80	47	24-52	Yes	Drinking water disinfectant by-product
Total Chlorine Residual	ppm	4 <sup>4</sup>	4 <sup>5</sup>	1.65	0.0 – 3.5	Yes	Drinking water disinfectant

<sup>1</sup>MCL is calculated based on locational running annual averages (LRAA) of samples collected from the last four quarters. <sup>2</sup>This number is the highest running annual average of quarterly compliance samples for the 2018 calendar year; for Total Chlorine Residual, the highest running annual average was determined by calculating quarterly values which were based on monthly compliance samples. <sup>3</sup>MCL exceedance is NOT determined based on individual results.

<sup>4</sup>MRDLG. <sup>5</sup>MRDL.

Turbidity	Unit	MCLG	MCL	Highest Level	Lowest monthly percentage of samples meeting the limit	Meets EPA Standards	Possible Source of Contamination
Turbidity*	NTU	n/a	<1.0 maximum, and ≤0.3 95% of the time	0.24	100%	Yes	Soil Run-off

\*Turbidity is a measure of the cloudiness of water. Turbidity, by itself, is not harmful, but it can interfere with the disinfection of drinking water.


Secondary and Unregulated Monitored Substances	Unit	SMCL	Highest Level	Average Level	Range	Likely Source
Aluminum	ppm	0.20	0.03	0.02	0.01-0.03	Erosion of natural deposits; also from use of chemicals at water treatment plant
Chloride	ppm	250	22	17	10-22	Natural in environment
Diethylphthalate	ppb	n/a	2.3	ND	ND-2.3	Agricultural Runoff
Foaming Agents	ppb	500	10	7	2-10	Natural in the environment
Iron	ppm	0.30	0.14	0.07	ND-0.14	Natural in environment
Manganese	ppm	0.050	0.007	ND	ND-0.007	Natural in environment
Metolachlor	ppm	n/a	0.1	ND	ND-0.1	Agricultural Runoff
Nickel	ppm	n/a	0.003	ND	ND-0.003	Corrosion of plumbing materials
pH (acidity)	pH units	6.5-8.5	7.8 <sup>1</sup>	7.7	7.3-8.1	Adjusted during water treatment process
Sodium	ppm	n/a <sup>2</sup>	26	15	10-26	Natural in environment; also from use of chemicals at water treatment plant
Sulfate	ppm	250	39	29	20-39	Natural in environment; also from use of chemicals at water treatment plant
Total Dissolved Solids	ppm	500	126	108	89-126	Natural in environment
Zinc	ppm	5	0.25	0.18	0.06-0.25	Natural in environment; also from use of chemicals at water treatment plant

<sup>1</sup> Highest monthly average for calendar year

<sup>2</sup> For physician-prescribed "no salt diets" a limit of 20 ppm is suggested.

Additional Information*	Unit	Average Level	Range
Alkalinity	ppm	27	17-37
Ammonia	ppm	0.1	ND-0.2
Hardness	ppm	47 <sup>1</sup>	32-64
Silica	ppm	6	3-9

\*The substances listed above are not regulated by the EPA; however, this information is provided as a service to our customers. <sup>1</sup> Norfolk's water averages in the range between soft and slightly hard. This means there is enough hardness for soaps and detergents to work properly, yet not too much to interfere with most industrial applications. To find grains per gallon, divide ppm value by 17.



Unregulated Contaminant Monitoring Rule 4 (UCMR4) *	Unit	SMCL	Highest Level	Average Level	Range
Manganese <sup>1</sup>	ppm	0.050	0.004	0.001	ND-0.004

\*This monitoring provides a basis for future regulatory actions to protect public health. Cyanotoxins such as Microcyst & Nodularins, Anatoxin-a and Cylindrospermopsin were also monitored, but these contaminants detected levels were less than their USEPA's set Minimum Reporting Levels (MRL). The MRL is used to provide the smallest measured concentration of contaminant that may be reliably reported by the lab using a given analytical method. <sup>1</sup> This value is included in the data used for the "Secondary and Unregulated Monitored Substances" table above, and also listed separately here to reflect the results of the four quarterly UCMR4 sampling events.

## VIOLATIONS AND EXCEEDANCES

There were no drinking water violations to report for 2018.

## QUESTIONS

Please contact NSN Environmental staff at 757-341-0479 and NSA HR HQ Complex Environmental staff at 757-836-1862 if you have any questions regarding this report.

To access this report electronically, please visit the Commander, Navy Region Mid-Atlantic website at: [http://www.cnrc.navy.mil/regions/cnrma/om/environmental\\_support/water\\_quality\\_information.html](http://www.cnrc.navy.mil/regions/cnrma/om/environmental_support/water_quality_information.html)