

**CRANEY ISLAND  
LEAD AND COPPER INDIVIDUAL RESULTS  
(June - September 2022)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	140	^Non-detect	5 <sup>th</sup> highest result = 165
2	288 - 1st Floor	^Non-detect	4 <sup>th</sup> highest result = 102
3	294	^Non-detect	84
4	82	^Non-detect	64
5	288 - 2nd Floor	^Non-detect	36

Compliance Calculation – Average 4<sup>th</sup> and 5<sup>th</sup> highest sample results

- **90<sup>th</sup> Percentile Lead Level = Non-detect**  
^The 90th Percentile for the lead samples are the Non-detect results.
- **90<sup>th</sup> Percentile Copper Level = 133.5 ppb**

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value