

**JEB LITTLE CREEK WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
July - September 2022	2 ppb - passed	399 ppb - passed
July - September 2019	3 ppb - passed	353 ppb - passed
July - September 2016	3 ppb - passed	220 ppb - passed
July - September 2013	3 ppb - passed	240 ppb - passed
July - September 2010	2 ppb - passed	159 ppb - passed
July - September 2009	4 ppb - passed	221 ppb - passed
July - September 2008	3 ppb - passed	227 ppb - passed
July - September 2007	4 ppb - passed	192 ppb - passed

ppb = parts per billion