



**DEPARTMENT OF THE NAVY**  
JOINT EXPEDITIONARY BASE LITTLE CREEK-FORT STORY  
2600 TARAWA COURT, SUITE 100  
VIRGINIA BEACH, VA 23459-3297

5090  
Ser N4/ 455  
26 Aug 22

**From:** Commander, Joint Expeditionary Base Little Creek-Fort Story  
**To:** Parents, Caregivers, and Staff

**Subj:** JOINT EXPEDITIONARY BASE LITTLE CREEK-FORT STORY CHILD  
DEVELOPMENT CENTER, BUILDING 3432, DRINKING WATER RESULTS

**Encl:** (1) Test Results Overview  
(2) Sample Summary of Results  
(3) Floor Plan of JEB Little Creek Child Development Center, Building 3432


1. Lead exposure is a particular concern for children. Lead in drinking water typically comes from the plumbing inside buildings including lead service lines, fittings, solder, water fountains/coolers, and water outlets. Navy policy requires we test the lead content of drinking water in priority areas such as youth centers, child development group homes, and child development centers (CDCs) every five years. Testing at the Joint Expeditionary Base (JEB) Little Creek CDC, Building 3432, was conducted on 22 July 2022.
2. I am pleased to report that all drinking water intended for consumption, to include water intended for cooking and/or washing, is at or below the Navy lead screening level of 15 parts per billion (ppb).
3. In total 109 samples were taken and tested. An overview and summary of all the test results are included as Enclosures (1) and (2). A building floor plan indicating of the locations the samples were taken from is included as Enclosure (3). You can also see a hard copy of our water testing results at the JEB Little Creek CDC, Building 3432, which is open Monday to Friday from (0500 to 1800).
4. For your information, below are links to additional drinking water quality resources:
  - a. Environmental Protection Agency (EPA) website: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.
  - b. Annual water quality report for the installation: <https://cnrma.cnmc.navy.mil/Operations-and-Management/Environmental-Support/Drinking-Water-Quality-Information/>.
  - c. To learn more about the installation's public water supplier, see their annual water quality report: <https://www.norfolk.gov/657/Water-Quality-Reports>.

Subj: JOINT EXPEDITIONARY BASE LITTLE CREEK-FORT STORY CHILD DEVELOPMENT CENTER, BUILDING 3432, DRINKING WATER RESULTS

d. To answer any questions you may have on the sampling program, contact the Joint Expeditionary Base Little Creek-Fort Story Public Affairs Officer at (757) 462-8425.

5. If you have any health related questions or concerns about lead exposure, I encourage you to contact your health care provider or if you are a TRICARE beneficiary, use the Hampton Roads Appointment Center to schedule an appointment with your primary care provider at 1 (866) 645-4584.

6. Please be assured that my team and I will continue to monitor and test water quality, as well as take actions where necessary at the CDC to ensure our drinking water complies with Navy policy and EPA regulations. I am committed to the safety and health of all personnel and family members using our facilities.

  
M. L. WITHERSPOON  
Captain, United States Navy  
Commander

Copy to:  
Commander, Navy Installations Command (N45)  
Naval Facilities (N45)  
Branch Health Clinic Boone  
Naval Medical Center Portsmouth  
Navy and Marine Corps Public Health Center (NMCPHC)

## Test Results Overview

### Overview of Testing Results for Lead in Drinking Water for JEB Little Creek CDC, Building 3432

The Navy is committed to maintaining safe drinking water on its installations. The City of Norfolk supplies water to the Navy and the Navy's water distribution system is regularly tested and in compliance with the Safe Drinking Water Act. Because lead exposure is a particular concern for children, and lead may be added to drinking water due to its presence in pipes, fittings, solder, and fixtures inside a building, the Navy policy requires that we test the lead content of drinking water in priority areas such as youth centers, child development group homes, and child development centers (CDCs) every five years.

Navy environmental personnel conducted lead testing at the Joint Expeditionary Base (JEB) Little Creek CDC Building 3432 in accordance with Navy and EPA guidelines. Samples from outlets in the CDC were sent to James R. Reed & Associates, a state-certified laboratory, for analysis.

At the JEB Little Creek CDC Building 3432, outlets used for drinking, cooking, and washing were tested. Out of **109** samples collected, no water outlets tested above the Navy screening level of 15 parts per billion (ppb) for lead in drinking water in schools and CDCs.

A copy of all test results is enclosed for your information. The test results are presented in two tables in Enclosure (2).

- Table 1 **Sample Summary of Results** summarizes the data by category of use (e.g., drinking, cooking, and washing).
- Table 2 **Summary Statistics** summarizes all the data.

**Table 1** provides a description of each sampling location using four columns; *Category*, *Outlet ID No.*, *Sampling ID*, and *Outlet Description*. The *Category* column gives information about whether the outlet is used for drinking water (water fountain), cooking (food preparation), or washing (primarily hand-washing). The *Outlet ID No.* is the inventory number for the outlets at the CDC. The *Sample ID* column is the identification used to label each sample bottle. The *Outlet Description* column contains additional information to describe the outlet sampled under each category.

The next set of columns in **Table 1** provide *Initial Sampling Results*.

EPA sampling protocol requires water to not be used for between 8 and 18 hours prior to first draw sampling. Therefore, *Initial Sampling Results were from* first draw samples collected early in the morning before the CDC opened and before any water was used.

A floor plan of the JEB Little Creek CDC Building 3432 has also been included, as Enclosure (3), to show the locations of the outlets tested.

Table 1. Sample Summary of Results  
Priority Areas Lead Testing  
JEB Little Creek Child Development Center, Building 3432

Table 1. Sample Summary of Results

SAMPLING LOCATION DESCRIPTION					INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	OUTLET ID NO.	SAMPLE ID	Outlet Description	Comments	First Draw (ppb)	Retest required?	Date Fixture Secured?	Lead Screening Level of 15 ppb			Description	Recommended Level = 15 ppb	
								Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE					7/15/2022				mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy
RESULTS DATE					7/29/2022				mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy
DRINKING	5	JEBLC-3432-LOUNGE145-FRIDGE-FD	Water dispenser from refrigerator in Staff Lounge 145		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	6	JEBLC-3432-HALL-WFBA-FD	Water fountain bubbler (low) in Hallway		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	7	JEBLC-3432-HALL-WFBB-FD	Water fountain bubbler (high) in Hallway		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	30	JEBLC-3432-RM128-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 128		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	36	JEBLC-3432-RM127-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 127		2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	42	JEBLC-3432-RM126-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 126		11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	48	JEBLC-3432-RM125-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	54	JEBLC-3432-RM124-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 124		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	60	JEBLC-3432-RM123-WFCOMB-FD	Water fountain outlet from combination sink in Toddler Room 123		3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	73	JEBLC-3432-RM117-WFCOMB-FD	Water fountain outlet from combination sink in Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	79	JEBLC-3432-RM116-WFCOMB-FD	Water fountain outlet from combination sink in Preschool Room 116		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DRINKING	85	JEBLC-3432-RM115-WFCOMB-FD	Water fountain outlet from combination sink in Preschool Room 115		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	4	JEBLC-3432-LOUNGE145-K-FD	Kitchen faucet used for food preparation and dishwashing in the Staff Lounge 145		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	65	JEBLC-3432-K120-KA-FD	Kitchen sink used for food preparation, dishwashing, and to fill water jugs in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	67	JEBLC-3432-K120-KB-FD	Kitchen sink used for food preparation and dishwashing in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	68	JEBLC-3432-K120-KC-FD	Kitchen sink used for food preparation in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
COOKING	69	JEBLC-3432-K120-KD-FD	Kitchen sink used for food preparation, dishwashing, and to fill water jugs in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	29	JEBLC-3432-RM128-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 128		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	35	JEBLC-3432-RM127-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 127		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	41	JEBLC-3432-RM126-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 126		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	47	JEBLC-3432-RM125-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	53	JEBLC-3432-RM124-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 124		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	59	JEBLC-3432-RM123-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Toddler Room 123		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	72	JEBLC-3432-RM117-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	78	JEBLC-3432-RM116-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Preschool Room 116		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	84	JEBLC-3432-RM115-HWCOMB-FD	Low handwashing faucet from combination sink (used for teeth brushing) in Preschool Room 115		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	1	JEBLC-3432-BATH148-HHW-FD	High handwashing faucet with motion sensor in Restroom 148		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	2	JEBLC-3432-BATH147-HHW-FD	High handwashing faucet with motion sensor in Restroom 147		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Table 1. Sample Summary Results  
Priority Areas Lead Testing  
JEB Little Creek Child Development Center, Building 3432

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS		
CATEGORY	OUTLET ID NO.	SAMPLE ID	Outlet Description	Comments	Lead Screening			Level of 15 ppb			Description	Recommended Level = 15 ppb	
					First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE				7/15/2022			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	mm/dd/yyyy	
RESULTS DATE				7/29/2022			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	mm/dd/yyyy	
WASHING	3	JEBLC-3432-BATH146-HHW-FD	High handwashing faucet with motion sensor in Restroom 146		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	8	JEBLC-3432-RM143-HHW-FD	High handwashing faucet in Infant Room 143		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	9	JEBLC-3432-BATH143-HHW-FD	High handwashing faucet with motion sensor in Infant Room 143		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	10	JEBLC-3432-RM142-HHWA-FD	High handwashing faucet in Infant Room 142		2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	11	JEBLC-3432-BATH142-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 142		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	12	JEBLC-3432-RM141-HHWA-FD	High handwashing faucet in Infant Room 141		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	13	JEBLC-3432-BATH141-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 141		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	14	JEBLC-3432-RM140-HHWA-FD	High handwashing faucet in Infant Room 140		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	15	JEBLC-3432-BATH140-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 140		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	16	JEBLC-3432-RM139-HHWA-FD	High handwashing faucet in Infant Room 139		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	17	JEBLC-3432-BATH139-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 139		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	18	JEBLC-3432-RM138-HHWA-FD	High handwashing faucet in Infant Room 138		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	19	JEBLC-3432-BATH138-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 138		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	20	JEBLC-3432-RM137-HHWA-FD	High handwashing faucet in Infant Room 137		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	21	JEBLC-3432-BATH137-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 137		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	22	JEBLC-3432-RM136-HHWA-FD	High handwashing faucet in Infant Room 136		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	23	JEBLC-3432-BATH136-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 136		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	24	JEBLC-3432-RM135-HHWA-FD	High handwashing faucet in Infant Room 135		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	25	JEBLC-3432-BATH135-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 135		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	26	JEBLC-3432-RM134-HHWA-FD	High handwashing faucet in Infant Room 134		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	27	JEBLC-3432-BATH134-HHWP-FD	High handwashing faucet with motion sensor in restroom within Infant Room 134		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	28	JEBLC-3432-RM128-HHW-FD	High handwashing faucet in Toddler Room 128		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	31	JEBLC-3432-BATH128-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 128		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	32	JEBLC-3432-BATH128-LHWP-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 128		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	33	JEBLC-3432-BATH128-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 128		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	34	JEBLC-3432-RM127-HHW-FD	High handwashing faucet in Toddler Room 127		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	37	JEBLC-3432-BATH127-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 127		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	38	JEBLC-3432-BATH127-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 127		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	39	JEBLC-3432-BATH127-LHWP-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 127		8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	40	JEBLC-3432-RM126-HHW-FD	High handwashing faucet in Toddler Room 126		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	43	JEBLC-3432-BATH126-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 126		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	44	JEBLC-3432-BATH126-LHWP-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 126		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	45	JEBLC-3432-BATH126-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 126		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	46	JEBLC-3432-RM125-HHW-FD	High handwashing faucet in Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Table 1. Sample Summary Results  
Priority Areas Lead Testing  
JEB Little Creek Child Development Center, Building 3432

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS		
CATEGORY	OUTLET ID NO.	SAMPLE ID	Outlet Description	Comments	First Draw (ppb)	Retest required?	Date Fixture Secured?	Lead Screening Level of 15 ppb			Description	Recommended Level = 15 ppb	
								Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE				7/15/2022			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	mm/dd/yyyy	
RESULTS DATE				7/29/2022			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	mm/dd/yyyy	
WASHING	49	JEBLC-3432-BATH125-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	50	JEBLC-3432-BATH125-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	51	JEBLC-3432-BATH125-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 125		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	52	JEBLC-3432-RM124-HHW-FD	High handwashing faucet in Toddler Room 124		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	55	JEBLC-3432-BATH124-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 124		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	56	JEBLC-3432-BATH124-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 124		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	57	JEBLC-3432-BATH124-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 124		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	58	JEBLC-3432-RM123-HHW-FD	High handwashing faucet in Toddler Room 123		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	61	JEBLC-3432-BATH123-HHW-FD	High handwashing faucet with motion sensor in restroom within Toddler Room 123		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	62	JEBLC-3432-BATH123-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 123		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	63	JEBLC-3432-BATH123-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Toddler Room 123		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	64	JEBLC-3432-K120-HHWA-FD	High handwashing faucet in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	66	JEBLC-3432-K120-HHWB-FD	High handwashing faucet in the Kitchen Room 120		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	70	JEBLC-3432-BATH119-HHW-FD	High handwashing faucet with motion sensor in Restroom 119		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	71	JEBLC-3432-RM117-HHW-FD	High handwashing faucet in Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	74	JEBLC-3432-BATH117-HHW-FD	High handwashing faucet with motion sensor in restroom within Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	75	JEBLC-3432-BATH117-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	76	JEBLC-3432-BATH117-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 117		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	77	JEBLC-3432-RM116-HHW-FD	High handwashing faucet in Preschool Room 116		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	80	JEBLC-3432-BATH116-HHW-FD	High handwashing faucet with motion sensor in restroom within Preschool Room 116		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	81	JEBLC-3432-BATH116-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 116		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	82	JEBLC-3432-BATH116-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 116		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	83	JEBLC-3432-RM115-HHW-FD	High handwashing faucet in Preschool Room 115		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	86	JEBLC-3432-BATH115-HHW-FD	High handwashing faucet with motion sensor in restroom within Preschool Room 115		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	87	JEBLC-3432-BATH115-LHWA-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 115		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	88	JEBLC-3432-BATH115-LHWB-FD	Low handwashing faucet with motion sensor in restroom within Preschool Room 115		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	89	JEBLC-3432-RM110-HHW-FD	High handwashing faucet in Pre-Toddler Room 110		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	90	JEBLC-3432-BATH110-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 110		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	91	JEBLC-3432-BATH110-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 110		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	92	JEBLC-3432-RM109-HHW-FD	High handwashing faucet in Pre-Toddler Room 109		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	93	JEBLC-3432-BATH109-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 109		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	94	JEBLC-3432-BATH109-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 109		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	95	JEBLC-3432-RM108-HHW-FD	High handwashing faucet in Pre-Toddler Room 108		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	96	JEBLC-3432-BATH108-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 108		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Table 1. Sample Summary Results  
 Priority Areas Lead Testing  
 JEB Little Creek Child Development Center, Building 3432

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS		
CATEGORY	OUTLET ID NO.	SAMPLE ID	Outlet Description	Comments	First Draw (ppb)	Retest required?	Date Fixture Secured?	Lead Screening Level of 15 ppb			Description	Recommended Level = 15 ppb	
								Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE				7/15/2022			mm/dd/yyyy			mm/dd/yyyy			
RESULTS DATE				7/29/2022			mm/dd/yyyy			mm/dd/yyyy			
WASHING	97	JEBLC-3432-BATH108-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 108		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	98	JEBLC-3432-RM107-HHW-FD	High handwashing faucet in Pre-Toddler Room 107		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	99	JEBLC-3432-BATH107-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 107		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	100	JEBLC-3432-BATH107-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 107		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	101	JEBLC-3432-RM106-HHW-FD	High handwashing faucet in Pre-Toddler Room 106		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	102	JEBLC-3432-BATH106-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 106		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	103	JEBLC-3432-BATH106-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 106		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	104	JEBLC-3432-RM105-HHW-FD	High handwashing faucet in Pre-Toddler Room 105	Outlet repaired and not leaking at time of sampling.	non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	105	JEBLC-3432-BATH105-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 105		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	106	JEBLC-3432-BATH105-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 105		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	107	JEBLC-3432-RM104-HHW-FD	High handwashing faucet in Pre-Toddler Room 104		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	108	JEBLC-3432-BATH104-HHW-FD	High handwashing faucet with motion sensor in restroom within Pre-Toddler Room 104		non-detect	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
WASHING	109	JEBLC-3432-BATH104-LHW-FD	Low handwashing faucet with motion sensor in restroom within Pre-Toddler Room 104		1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS			POST REMEDIATION
	Lead Screening Level of 15 ppb					First Draw (ppb)
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	
Total Drinking	12	N/A	N/A	N/A	N/A	
Total Drinking > 15 ppb	0	N/A	N/A	N/A	N/A	
Total Cooking	5	N/A	N/A	N/A	N/A	
Total Cooking > 15 ppb	0	N/A	N/A	N/A	N/A	
Total Washing	92	N/A	N/A	N/A	N/A	
Total Washing > 15 ppb	0	N/A	N/A	N/A	N/A	
Total Samples	109	N/A	N/A	N/A	N/A	
Total Samples > 15 ppb	0	N/A	N/A	N/A	N/A	

# Floor Plan of JEB Little Creek Child Development Center, Building 3432

