

**NWSY, CHEATHAM ANNEX WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2016)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	115	13	35
2	225	90 th Percentile = 7	463
3	108	5	54
4	1	5	61
5	235	3	485
6	295	3	11
7	130	2	1240
8	284	2	679
9	213	1	90th Percentile = 848
10	270	Non-detect	452

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value