

**CRANEY ISLAND WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
July – December 2013	1 ppb – Passed	243 ppb - Passed
June – September 2010	3 ppb – Passed	253 ppb - Passed
June – September 2007	2 ppb – Passed	234 ppb - Passed
June – September 2005	1 ppb – Passed	123 ppb - Passed

ppb = parts per billion