

**JEB LITTLE CREEK WATERWORKS
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
July – September 2016	3 ppb - passed	284 ppb - passed
July – September 2013	3 ppb - passed	220 ppb - passed
June – September 2010	2 ppb - passed	159 ppb - passed
June – September 2009 (First Reduced)	4 ppb - passed	221 ppb – passed
June – September 2008 (Second initial)	3 ppb - passed	227 ppb – passed
June – September 2007 (First initial)	4 ppb – passed	192 ppb - passed

ppb = parts per billion