

**NAVAL STATION NEWPORT
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2017)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	541 Read St	3	60
2	2 Columbia Ct	<1	< 10
3	3 Columbia Ct	<1	20
4	61 Mayflower	<1	20
5	34 Constellation	2	10
6	B360 North	<1	30
7	B360 South	46	50
8	Melville Comm Ctr	<1	130
9	B369 Green Ln	2	50
10	192 Jones St	<1	<10
11	B76 Communications	4	50
12	B1260 FFSC	40	20
13	B10 NWC Museum	2	<10
14	B12 NWC Warehouse	<1	<10
15	152 Jones Street	<1	40
16	Building 1 CC	24	60
17	B1246 NUWC	<1	30
18	B29 Sims Hall	1	220
19	B52 Schonland Hall	54	330
20	B991 Hewitt Hall	1	50
21	B165 NUWC	1	80
22	B101 NUWC	<1	30

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value

The 90th Percentile for the lead samples is 40 ppb.

The 90th Percentile for the lead samples is 130 ppb.