

NSA Crane**Historical Lead and Copper Results**

Monitoring Period	Lead 90th Percentile Action Level 15 ppb	Copper 90th Percentile Action Level 1300 ppb
June - September 2017	3 ppb - Passed	61 ppb - Passed
June - September 2014	8.1 ppb - Passed	80 ppb - Passed
June - September 2011	6 ppb - Passed	135 ppb - Passed
June - September 2008	6 ppb - Passed	890 ppb - Passed
June - September 2005	5 ppb - Passed	95 ppb - Passed
June - September 2002	3 ppb - Passed	121 ppb - Passed
June - September 1996	<5 ppb - Passed	40 ppb - Passed
June - September 1992	1 ppb - Passed	95 ppb - Passed