

NAVAL SUPPORT ACTIVITY, NALF FENTRESS
LEAD AND COPPER INDIVIDUAL RESULTS
(July - September 2023)

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	Room #4	Non-Detect	248
2	Room A (LCPO)	1	629
3	Room #11	Non-Detect	491
4	Room #6	Non-Detect	460
5	Galley deep sink	90 th percentile - 1	636
6	Room #4	Non-detect	397
7	Galley deep sink	Non-detect	90 th percentile - 634
8	Galley Scullery	Non-Detect	523
9	Room #7	Non-Detect	598
10	Room #10	Non-Detect	549

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value