

**NAVAL STATION GREAT LAKES  
LEAD AND COPPER INDIVIDUAL RESULTS  
(June – September 2023)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	LA3S080	^Non-detect	300
2	LA3S098	^Non-detect	260
3	LA3S075	^Non-detect	260
4	LA3S090	^Non-detect	90 <sup>th</sup> percentile - 260
5	LA3S100	^Non-detect	210
6	LA3S074	^Non-detect	210
7	LA3S093	^Non-detect	110
8	LAS084	^Non-detect	110
9	LA3S081	^Non-detect	100
10	LA3S101	^Non-detect	100
11	LA3S073	^Non-detect	91
12	LA3S092	^Non-detect	70
13	LA3S085	^Non-detect	62
14	LA3S097	^Non-detect	41
15	LA3S099	^Non-detect	33
16	LA3S091	^Non-detect	26
17	LA3S083	^Non-detect	24
18	LA3S096	^Non-detect	17
19	LA3S072	^Non-detect	17
20	LA3S088	^Non-detect	13
21	LA3S095	^Non-detect	13
22	LA3S086	^Non-detect	12
23	LA3S089	^Non-detect	11
24	LA3S079	^Non-detect	10
25	LA3S087	^Non-detect	10
26	LA3S078	^Non-detect	9.9
27	LA3S071	^Non-detect	9.6
28	LA3S076	^Non-detect	9.6
29	LA3S124	^Non-detect	9.4
30	LA3S094	^Non-detect	8.9

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90<sup>th</sup> percentile value

Copper Action Level = 1300 ppb based on the 90<sup>th</sup> percentile value

^The 90<sup>th</sup> Percentile for the lead samples are the Non-detect results.