

Priority Areas Lead Testing and Corrective Actions (AUGUST 2017)
PORTSMOUTH NAVAL SHIPYARD, Child Development Center, Modular Classrooms
BLDG R-83

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION					INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING	
CATEGORY Water Intended For:	BUILDING	ROOM	SAMPLE ID	Outlet Description	Recommended Level = 20ppb								
					First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
					Detection Limit = 1 ppb					Detection Limit = 1 ppb		Detection Limit = 1 ppb	Detection Limit = 1 ppb
				SAMPLING DATE ----> RESULTS DATE ---->	08/08/2017 08/08/2017			NA NA	NA NA	NA NA			
WASHING	R83	CLASSROOM 1	PSY-R83-BATH1-LHW-FD-01	BATHROOM CHILD SINK 1	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 1	PSY-R83-BATH1-LHW-FD-02	BATHROOM CHILD SINK 2	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 1	PSY-R83-BATH1-HHW-FD-03	BATHROOM CHANGING STATION SINK	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 1	PSY-R83-RM1-HHW-FD-04	CLASSROOM COUNTER SINK	2	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 1	PSY-R83-RM1-HWCMB-FD-05	CLASSROOM CHILD SINK	3	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
DRINKING	R83	CLASSROOM 1	PSY-R83-RM1-WFCMB-FD-06	DRINKING FOUNTAIN A (BUBBLER)	2	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 2	PSY-R83-BATH2-LHW-FD-07	BATHROOM CHILD SINK 1	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 2	PSY-R83-BATH2-LHW-FD-08	BATHROOM CHILD SINK 2	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 2	PSY-R83-BATH2-HHW-FD-09	BATHROOM CHANGING STATION SINK	<1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 2	PSY-R83-RM2-HHW-FD-10	CLASSROOM COUNTER SINK	1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	CLASSROOM 2	PSY-R83-RM2-HWCMB-FD-11	CLASSROOM CHILD SINK	3	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
DRINKING	R83	CLASSROOM 2	PSY-R83-RM2-WFCMB-FD-12	DRINKING FOUNTAIN B (BUBBLER)	1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA
WASHING	R83	ENTRANCE/HALLWAY	PSY-R83-BATH-HHW-FD-13	ADULT RESTROOM SINK	1	NO	NA	NA	NA	NA	Routine Control Measures Only	NA	NA

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS Sample Date: 08/08/2017	RE-SAMPLING RESULTS (For Samples >20 ppb) Sample Date: NA			POST REMEDIATION RESULTS
	First Draw Samples Taken	First Draw > 20 ppb	Water Fountain Follow up Flush Sample- Collected day before First Draw Sampling	Follow up Flush Collected 30 seconds after First Draw Sampling > 20 ppb	First Draw > 20 ppb
Total Drinking	2	NA	NA	NA	NA
Total Drinking > 20 ppb	0	NA	NA	NA	NA
Total Washing	11	NA	NA	NA	NA
Total Washing > 20 ppb	0	NA	NA	NA	NA
Total Samples	13	NA	NA	NA	NA
Total Samples > 20 ppb	0	NA	NA	NA	NA