

**JEB LITTLE CREEK WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2022)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	Navy Bldg 4075 (4911 Safi Circle)	8	112
2	3364	3	90 th Percentile = 399
3	Navy Bldg 4153 (5024 Gela)	90 th Percentile = 2	102
4	3872	2	480
5	3816	2	249
6	3604	1	319
7	3821	1	165
8	Navy Bldg 5038 (5038C Gunter)	Non-detect	456
9	3812	Non-detect	338
10	1602	Non-detect	169
11	3814	Non-detect	134
12	3603	Non-detect	113
13	3870	Non-detect	78
14	CB301	Non-detect	78
15	Navy Bldg 5047 (5047A Pemberton)	Non-detect	62
16	CB310	Non-detect	62
17	3820	Non-detect	58
18	1265	Non-detect	44
19	Navy Bldg 4171 (5014 Gela Drive)	Non-detect	40
20	Navy Bldg 4053 (2215 Casablanca Rd)	Non-detect	20

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value