

NAS OCEANA WATERWORKS LEAD AND COPPER INDIVIDUAL RESULTS (June – September 2024)		
Sampling Site	Lead (ppb)	Copper (ppb)
B. 321	2	249
B.330	90 th Percentile - 2	90 th Percentile – 196
1791 F Avenue	2	38
B.536	1	401
B 1105	Non-detect	155
B.333	Non-detect	116
1004 F Avenue	Non-detect	80
1798 F Avenue	Non-detect	71
983 F Avenue	Non-detect	70
1789 F Avenue	Non-detect	68
978 F Avenue	Non-detect	64
1042 F Avenue	Non-detect	62
1797 F Avenue	Non-detect	58
1041 F Avenue	Non-detect	57
1807 F Avenue	Non-detect	57
1016 F Avenue	Non-detect	56
1061 F Avenue	Non-detect	55
986 F Avenue	Non-detect	47
1021 F Avenue	Non-detect	35
984 F Avenue	Non-detect	22
ppb = parts per billion Lead Action Level = 15 ppb based on the 90 th percentile value Copper Action Level = 1300 ppb based on the 90th percentile value		