

**NAVAL STATION NEWPORT
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 th Percentile (Action Level: 1300 ppb)
June – September 2024	4 ppb - Passed	58 ppb - Passed
June – September 2023	5 ppb - Passed	34 ppb - Passed
June – September 2022	4 ppb - Passed	110 ppb - Passed
June – September 2021	7 ppb - Passed	151 ppb - Passed
June – September 2020	9 ppb - Passed	87 ppb - Passed
June – September 2019	10 ppb - Passed	146 ppb - Passed
July – December 2018	14 ppb - Passed	85 ppb - Passed
January – June 2018	8 ppb - Passed	130 ppb - Passed
June – September 2017	40 ppb - Failed	130 ppb - Passed
June – September 2014	10 ppb - Passed	120 ppb - Passed
June – September 2011	4 ppb - Passed	80 ppb - Passed

ppb = parts per billion