

**NAVAL STATION NEWPORT
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2024)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	NWC B29 Sims Hall	14	39
2	NWC B52 Schonland Hall	8	256
3	NJS B360 CP South	7	120
4	NWC B10 Founders Hall	90 th Percentile = 4	27
5	NMRTC NE B23	2	60
6	B76 CC Communications	2	37
7	Quarters NB-1	2	29
8	NUWC B101	2	26
9	B369 Greene Lane	2	16
10	B1CC Public Works	1	28
11	B347 CP Navy Band	1	22
12	36 Chases Lane	1	17
13	Melville CC	<1	90 th Percentile = 58
14	3 Columbia Court	<1	43
15	NWC B991 Hewitt Hall	<1	34
16	B1314 CP UH	<1	31
17	NUWC B1246	<1	29
18	61 Mayflower Drive	<1	27
19	B1312 CP UH	<1	26
20	B668 CP UH	<1	26
21	NJS B1288 CP	<1	23
22	NJS B360 CP North	<1	23
23	38 Puritan Drive	<1	21
24	B1354 CP Navy Lodge	<1	18
25	B689 CP UH	<1	16
26	32 Chases Lane	<1	14
27	NGIS B442 CHI	<1	12
28	NGIS B443 CHI	<1	11
29	28 Chases Lane	<1	11
30	192 Jones Street	<1	8
31	B1313 CP UH	<1	4
32	B12 CC NWC Warehouse	<1	<5

ppb = parts per billion
Lead Action Level = 15 ppb based on the 90th percentile value
Copper Action Level = 1300 ppb based on the 90th percentile value
The 90th Percentile for the lead samples is 4 ppb.
The 90th Percentile for the copper samples is 58 ppb.