

**NAVAL STATION NORFOLK WATERWORK
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2022)**

| No. | Sampling Site | Lead (ppb) | Copper (ppb) |
|-----|---------------|---------------------------------|-----------------------------------|
| 1 | SP367 | 28 | 361 |
| 2 | SP12 | 9 | 108 |
| 3 | SP356 | 3 | 172 |
| 4 | P72 | 90 th Percentile = 3 | 50 |
| 5 | X380 | 2 | 140 |
| 6 | SP312 | 2 | 90 |
| 7 | C7 | 2 | 60 |
| 8 | N30 | 1 | 278 |
| 9 | A127 | 1 | 43 |
| 10 | CEP87 | Non-Detect | 229 |
| 11 | Q50 | Non-Detect | 90 th Percentile = 181 |
| 12 | LF53 | Non-Detect | 161 |
| 13 | SP30 | Non-Detect | 136 |
| 14 | CEP204 | Non-Detect | 125 |
| 15 | X218 | Non-Detect | 117 |
| 16 | O25 | Non-Detect | 114 |
| 17 | SP381 | Non-Detect | 109 |
| 18 | O22 | Non-Detect | 93 |
| 19 | SP91 | Non-Detect | 82 |
| 20 | CEP166 | Non-Detect | 82 |
| 21 | CEP156 | Non-Detect | 80 |
| 22 | W388 | Non-Detect | 79 |
| 23 | SP362 | Non-Detect | 78 |
| 24 | CEP162 | Non-Detect | 70 |
| 25 | CEP201 | Non-Detect | 63 |
| 26 | CD3 | Non-Detect | 54 |
| 27 | X275 | Non-detect | 52 |
| 28 | CEP195 | Non-detect | 45 |
| 29 | CD9 | Non-detect | 42 |
| 30 | CEP200 | Non-detect | 20 |

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value