

**NWSY, CHEATHAM ANNEX WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2022)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	284	324	10700
2	200	90 th Percentile = 4	299
3	235	1	383
4	109	Non-Detect	90 th Percentile = 561
5	270	Non-Detect	238
6	195	Non-Detect	126
7	201	Non-Detect	70
8	250	Non-Detect	58
9	1	Non-Detect	44
10	115	Non-detect	7

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value