

**NAVAL WEAPONS STATION YORKTOWN (NWSY)
WATERWORKS
LEAD AND COPPER INDIVIDUAL RESULTS
(June - September 2022)**

No.	Sampling Site	Lead (ppb)	Copper (ppb)
1	1923F	2	167
2	1929B	90 th Percentile = Non-detect	90 th Percentile = 88
3	1930F	Non-detect	75
4	1924E	Non-detect	72
5	1915C	Non-detect	57
6	1953C	Non-detect	50
7	1948C	Non-detect	48
8	1928A	Non-detect	47
9	1920C	Non-detect	33
10	1935A	Non-detect	30
11	1919B	Non-detect	28
12	1916C	Non-detect	18

ppb = parts per billion

Lead Action Level = 15 ppb based on the 90th percentile value

Copper Action Level = 1300 ppb based on the 90th percentile value