

**NAVAL WEAPONS STATION YORKTOWN WATERWORKS  
HISTORICAL LEAD AND COPPER RESULTS**

Monitoring Period	Lead 90th Percentile (Action Level: 15 ppb)	Copper 90 <sup>th</sup> Percentile (Action Level: 1300 ppb)
June – September 2022	Non-detect - Passed	53 ppb – Passed
June – September 2019	2 ppb - Passed	88 ppb – Passed
June – September 2016	2 ppb - Passed	57 ppb - Passed
June – September 2013	Non-detect - Passed	34 ppb - Passed
June – September 2010	Non-detect - Passed	86 ppb - Passed
June – September 2007	5 ppb - Passed	99 ppb - Passed

ppb = parts per billion